

# Texas Commission on Environmental Quality

## Public Notification Form for Wastewater Discharges

### Information about the Discharge

An unauthorized discharge or spill of wastewater has occurred from:

Wastewater Treatment Facility: \_\_\_\_\_ Collection System:  X

Facility Name: City of Runaway Bay

Person to contact for information: City of Runaway Bay (940) 575-4745

Location of spill(s): *109 Bay Roc*

Estimated date and time of spill(s): 5/24/22 7:40pm

Estimated volume of spill(s)(number of gallons): 50,000 gal

Type of Spill (domestic, industrial, other): Domestic Waste Water

Description of the area potentially affected, including down gradient and lateral distance from spill(s) site: The potential affected area is approximately 65 feet long and 32 feet wide at the widest point starting at GPS 33.175317 -97.876813 heading down hill northeast to the lake. Total area affected is approximately 1639 sq feet including a private beach area.

Suspected cause of spill(s): Heavy Rain Infiltration to collection system

### List of actions taken including but, not limited to:

Notification of:

Appropriate local government officials:  X  TCEQ Regional Office:  X

Containment of spill: Waste Water Bacteria

Increased monitoring of water supply systems: E.coli sampling

Initiation or completion of cleanup activities: 5/25/22 Public Works cleaned up site and disinfected area.

§319.302(b)(2)(A)

(b) In addition to the noncompliance notification to the commission required by §305.125(9) of this title (relating to Standard Permit Conditions) and any notification required under Chapter 327 of this title (relating to Spill Prevention and Control), the owner of a facility, through its responsible individual, must notify appropriate local government officials and the local media (see §319.301 of this title (relating to Definitions)) whenever one of the following types of spills occurs from the facility:

(2) a spill with a volume of 50,000 gallons or more where one or more of the following conditions also exists:

(A) the spill occurs within 1/2-mile of a public or private source of drinking water;

1. Persons using private drinking water supply wells located within ½ mile of the spill site or within the potentially affected area should use only water that has been distilled or boiled at a rolling boil for at least one minute for all personal uses including drinking, cooking, bathing, and tooth brushing. Individuals with private water wells should have their well water tested and disinfected, if necessary, prior to discontinuing distillation or boiling.
2. Persons who purchase water from a public water supply may contact their water supply distributor to determine if the water is safe for personal use.
3. The public should avoid contact with waste material, soil, or water in the area potentially affected by the spill.
4. If the public comes into contact with waste material, soil, or water potentially affected by the spill, they should bathe and wash clothes thoroughly as soon as possible.